

Map ID
Direction
Distance
Elevation

MAP FINDINGS

EDR ID Number
EPA ID Number

DO573
WSW
1/2-1
0.862 mi.
4549 ft.

CON EDISON VAULT #589
WEST 28TH STREET & MERMAID AVENUE
BROOKLYN, NY

NY Spills **S112226397**
N/A

Site 2 of 2 in cluster DO

Relative:
Higher

Actual:
2 ft.

SPILLS:

Name: CON EDISON VAULT #589
Address: WEST 28TH STREET & MERMAID AVENUE
City,State,Zip: BROOKLYN, NY
Spill Number/Closed Date: 1205590 / 2014-09-25
Facility ID: 1205590
Facility Type: ER
DER Facility ID: 422860
Site ID: 468549
DEC Region: 2
Spill Cause: Unknown
Spill Class: D4
SWIS: 2401
Spill Date: 2012-09-05
Investigator: RWAUSTIN
Referred To: Not reported
Reported to Dept: 2012-09-05
CID: Not reported
Water Affected: Not reported
Spill Source: Commercial/Industrial
Spill Notifier: Responsible Party
Cleanup Ceased: Not reported
Cleanup Meets Std: False
Last Inspection: Not reported
Recommended Penalty: False
UST Trust: False
Remediation Phase: 0
Date Entered In Computer: 2012-09-05
Spill Record Last Update: 2014-09-25
Spiller Name: ERT
Spiller Company: CON EDISON
Spiller Address: Not reported
Spiller Company: 999
Contact Name: ERT
DEC Memo: "9/4/12-Vought-Primary off hours responder. This spill assigned to DEC Feroze as part of routine Con Edison minor spill portfolio review and possible closure. Initial EMIS #230931 added to Cross Reference Field, deleted from Proxy and downloaded into E-docs. As per EMIS, F.O.D. Mech Mr. Dacon reports while being sent to phase check VS5589 (11B03) he discovered 30 gal of unknown oil in structure on 50 gal. of water contained. Possible source to be the unit and a pressure test is required. It is possible this structure is a tide hole as well. E-tag# 105972 was hung and a liquid sample of the structure was taken C/C# GG36440. Acct#C3237. N/P Tues & Friday 8:00 - 9:30 Am. See also duplicate spill 1205589 at same site. 9/25/14 - Austin - 30 gals motor oil (oil cans found in vicinity) atop 50 gals water in vault - Con Ed contained and cleaned up the spill - See the document files for further information - Spill closed - end"
Remarks: "Spill is contained in a cement vault. Believed to have been caused by tidal water. There is approx 50 gallons of water in the vault also."

All Materials:
Site ID:

468549

Map ID
Direction
Distance
Elevation

MAP FINDINGS

Site

Database(s)

EDR ID Number
EPA ID Number

Operable Unit ID: 1218469
Operable Unit: 01
Material ID: 2216846
Material Code: 0066A
Material Name: unknown petroleum
Case No.: Not reported
Material FA: Petroleum
Quantity: 30.00
Units: G
Recovered: Not reported
Oxygenate: Not reported